



TRANSMISSION POLE MAINTENANCE AREA

1. COMPLIANCE WITH ALL NESC & OSHA REQUIREMENTS.
2. MATERIALS AND EQUIPMENT CAN NOT BE STOCKPILED UNDER LINES.
3. POLE BOLLARDS ARE REQUIRED AND SHALL BE INSTALLED BY THE OWNER IF PARKING IS WITHIN 10' OF ANY TRANSMISSION STRUCTURE.
4. A 40'x40' LEVEL AND UNOBSTRUCTED AREA, ORIENTED ON CENTER OF POLE, MUST BE MAINTAINED ON ALL DEADEND STRUCTURES TO ALLOW ACCESS FOR MAINTENANCE PURPOSES. (SEE DETAIL ABOVE FOR CLARIFICATION)

DRAWING INFO.		
DRAWN	01/24/01	PH
DESIGNED	01/24/01	MDV
CHECKED	04/07/01	SA
APPROVED	04/07/01	SA
	DATE	BY
REV. 2	08/08/10	AC



NV ENERGY CRITERIA FOR MAINTENANCE ACCESS DEADEND STRUCTURE

SHEET: 1 OF 1

DWG. NO.: STD-D3