



TRANSMISSION POLE
MAINTENANCE AREA

1. COMPLIANCE WITH ALL NESC & OSHA REQUIREMENTS.
2. MATERIALS AND EQUIPMENT CAN NOT BE STOCKPILED UNDER LINES.
3. POLE BOLLARDS ARE REQUIRED AND SHALL BE INSTALLED BY THE OWNER IF PARKING IS WITHIN 10' OF ANY TRANSMISSION STRUCTURE.
4. A 40'x40' LEVEL AND UNOBSTRUCTED AREA, ORIENTED WITH TRANSMISSION CENTER LINE, MUST BE MAINTAINED ON ALL TANGENT STRUCTURES TO ALLOW ACCESS FOR MAINTENANCE PURPOSES. (SEE DETAIL ABOVE FOR CLARIFICATION)

DRAWING INFO.		
DRAWN	01/24/01	PH
DESIGNED	01/24/01	MDV
CHECKED	04/07/03	SA
APPROVED	04/07/03	SA
	DATE	BY
REV. 2	08/05/10	AC



NV ENERGY CRITERIA FOR
MAINTENANCE ACCESS
TANGENT STRUCTURE

SHEET: 1 OF 1

DWG. NO.: STD-D4