


SUBDIVISION PUBLIC UTILITY EASEMENT STAKING DETAIL



1. APPLICANT TO FURNISH PROPERTY LINE CHISEL MARK ON CURB.
2. FRONT PUE TO BE 7.5' MINIMUM, SIDELOT PUE TO BE 5' MINIMUM AND OTHERS AS REQUESTED.
3. OFFSET STAKES 10' TO 15' BY APPLICANT.

DRAWN	DESIGN	SUPR	DATE	REV
JL	JF	SJ	5/04	6

ENGINEERING & CONSTRUCTION STANDARD

**SUBDIVISION
PUBLIC UTILITY EASEMENT
STAKING DETAIL**

SHEET 7 OF 50

VOLUME 17

DRAWING NUMBER
GI0002U

**THIS PAGE LEFT
INTENTIONALLY BLANK**

Sierra Pacific
POWER COMPANY



ENGINEERING & CONSTRUCTION STANDARD

SHEET 8 OF 50

SUBDIVISION

VOLUME 17

**PUBLIC UTILITY EASEMENT
STAKING DETAIL**

DRAWING NUMBER

GI0002U

DRAWN	DESIGN	SUPR	DATE	REV
JL	JF	SJ	5/04	6