

# SECTION 6 EQUIPMENT PADS AND STREET LIGHT BASES

## CONTENTS

### PAD & WELL DETAILS FOR TRANSFORMERS, SWITCHES, & JE'S - PADMASTER

1.0	INDEX .....	SHEET 3
2.0	PURPOSE .....	SHEET 3
3.0	PAD DIMENSIONS .....	SHEET 3
	SPPC STOCK # 24-0691 .....	SHEET 3
	SPPC STOCK # 24-0692 .....	SHEET 3
	SPPC STOCK # 24-0694 .....	SHEET 4
	SPPC STOCK # 24-0697 .....	SHEET 4
	SPPC STOCK # 24-0726 .....	SHEET 4
	SPPC STOCK # 24-0728 .....	SHEET 4
	SPPC STOCK # 24-0732 .....	SHEET 5
	SPPC STOCK # 24-0736 .....	SHEET 5
	SPPC STOCK # 24-0730 .....	SHEET 5
	SPPC STOCK # 24-0734 .....	SHEET 5
	SPPC STOCK # 24-0738 .....	SHEET 6
	SPPC STOCK # 24-0731 .....	SHEET 6
	SPPC STOCK # 24-0722 .....	SHEET 6
	SPPC STOCK # 24-0721 .....	SHEET 6
	SPPC STOCK # 24-0724 .....	SHEET 7
	SWITCH REFERENCE TABLE .....	SHEET 7

### TRANSFORMER & SWITCH PAD- FIELD CAST REQUIREMENTS - PAD01X

	FIELD CAST REQUIREMENTS FOR SPPC STOCK # 24-0692	
	AND STOCK # 24-0694 .....	SHEET 9

### 3Ø TRANSFORMER PAD- FIELD CAST REQUIREMENTS - PAD02X

	FIELD CAST REQUIREMENTS FOR SPPC STOCK # 24-0697 .....	SHEET 11
--	--	----------

### 3Ø SWITCH PAD - FIELD CAST REQUIREMENTS - PAD03X

	FIELD CAST REQUIREMENTS FOR SPPC STOCK # 24-0726	
	STOCK # 24-0728, STOCK # 24-0732, AND STOCK # 24-0736 .....	SHEET 13

### TRANSFORMER PAD 1Ø 25-167 KVA - PE0001U

	PAD ELEVATION AND ISOMETRIC DETAILS .....	SHEET 15
	CONSTRUCTION AND ENGINEERING NOTES .....	SHEET 16

### TRANSFORMER PADS 3Ø 75-2500 KVA - PE0003U, PE0006U

	PAD ELEVATION AND ISOMETRIC DETAILS .....	SHEET 17
	CONSTRUCTION AND ENGINEERING NOTES .....	SHEET 18

### PADMOUNTED APPARATUS BARRIER POST - PE0009U

1.0	INDEX .....	SHEET 19
2.0	PURPOSE .....	SHEET 19
3.0	BARRIER POST GUIDELINES .....	SHEET 19
4.0	BARRIER POST INSTALLATION .....	SHEET 19
5.0	TRANSFORMER & SWITCH PAD REQUIREMENTS .....	SHEET 20

				
DRAWN	DESIGN	SUPR	DATE	REV
JL	MB	DA	7/05	04

<b>ENGINEERING &amp; CONSTRUCTION STANDARD</b> <b>ELECTRIC INSTALLATION</b> <b>GUIDE SECTION 6</b> <b>INDEX</b>
--

SHEET <u>1</u> OF 48
VOLUME 17
DRAWING NUMBER <b>INDEX</b>

**PADMOUNT EQUIPMENT LOCATIONS & CLEARANCES - PE0010U**

MINIMUM DISTANCE REQUIREMENTS TABLE ..... SHEET 21  
 PADMOUNT EQUIPMENT LINE OF SIGHT TRIANGLE ..... SHEET 22  
 DOOR AND FIRE ESCAPE CLEARANCE REQUIREMENTS ..... SHEET 23  
 AIR INTAKE OR EXHAUST CLEARANCE REQUIREMENTS ..... SHEET 24  
 WINDOW OR OPENING CLEARANCES ..... SHEET 24  
 LIMITED PEDESTRIAN TRAFFIC DOORS OR  
 GARAGE DOOR CLEARANCES ..... SHEET 24

**200 AMP 3Ø SWITCH PAD - PE0012U, PE0013U, PE0014U, PE0015U**

PAD ELEVATION AND ISOMETRIC DETAILS ..... SHEET 25  
 CONSTRUCTION AND ENGINEERING NOTES ..... SHEET 26

**600 AMP 3Ø SWITCH PAD WELL DETAIL - PE0016U, PE0017U, PE0018U**

PAD ELEVATION AND ISOMETRIC DETAILS ..... SHEET 27  
 CONSTRUCTION AND ENGINEERING NOTES ..... SHEET 28

**PRIMARY METERING 200 / 600 AMP 3Ø PAD DETAIL - PE0023U**

PAD ELEVATION AND ISOMETRIC DETAILS ..... SHEET 29  
 CONSTRUCTION AND ENGINEERING NOTES ..... SHEET 30

**JUNCTION ENCLOSURE PAD 1Ø / 3&4 WIRE - 3Ø 4 WIRE - PE0025U**

PAD ELEVATION AND ISOMETRIC DETAILS ..... SHEET 31  
 CONSTRUCTION AND ENGINEERING NOTES ..... SHEET 31  
 ISOMETRIC DIMENSION DETAILS ..... SHEET 32

**FIBERGLASS JUNCTION ENCLOSURE DETAIL 1Ø & 3Ø - PE0026U**

PAD ELEVATIONS AND CONDUIT DETAILS ..... SHEET 33  
 CONSTRUCTION AND ENGINEERING NOTES ..... SHEET 34

**200A / 600A 3Ø INTERRUPTER PAD DETAIL - PE0030U**

PAD ELEVATION AND ISOMETRIC DETAILS ..... SHEET 35  
 CONSTRUCTION AND ENGINEERING NOTES ..... SHEET 36

**O/H & U/G STREET LIGHT BASE DETAIL  
 FOR BOLTED BASE POLES - SLB02U & ODL30H**

STREET LIGHT LOCATION AND DESIGN INFORMATION ..... SHEET 37  
 O/H & U/G STREET LIGHT BASE DETAIL ..... SHEET 38

**BASE DETAIL FOR NDOT TYPE 7 BOLTED BASE POLES - SLB03U**


STREET LIGHT BASE DETAIL ..... SHEET 39

**UNDERGROUND DECORATIVE STREET LIGHT BASE - SLB12U**

PRECAST BASE ELEVATION DETAILS ..... SHEET 41

**RETAINING WALL DETAILS AND SLOPE MODIFICATIONS  
 FOR PADMOUNTED EQUIPMENT AND VAULTS - TE0040U**

CONSTRUCTION NOTES ..... SHEET 43  
 WALL DETAILS  
 RETAINING WALL INSTALLATION REQUIRING FILL ..... SHEET 44  
 RETAINING WALL INSTALLATION REQUIRING CUT ..... SHEET 44  
 TYPICAL WALL SECTION MAXIMUM HEIGHT 5'-4" ..... SHEET 45  
 TYPICAL WALL SECTION MAXIMUM HEIGHT 3'-4" ..... SHEET 45  
 TYPICAL WING WALL SECTION MAXIMUM HEIGHT 5'-4" ..... SHEET 46  
 TYPICAL WING WALL SECTION MAXIMUM HEIGHT 3'-4" ..... SHEET 46  
 REDWOOD LANDSCAPE WALLS ..... SHEET 47



DRAWN	DESIGN	SUPR	DATE	REV
JL	MB	DA	7/05	04

ENGINEERING & CONSTRUCTION STANDARD

**ELECTRIC INSTALLATION  
 GUIDE SECTION 6  
 INDEX**

SHEET 2 OF 48

VOLUME 17

DRAWING NUMBER  
**INDEX**