



Vaults and Boxes

INSTALLATION REQUIREMENTS

APPROVED STRUCTURE	
MANUFACTURER	MANHOLE
Jensen Precast	J-RS-97
Rockway Precast	R-RS-97




				Electric Service Requirements		RS-98
				12kV Manhole Pad: Adjacent to Public R.O.W.		
Drawn:	Eng:	Appr:	Date:	Revision: 1		Page 1 of 2
DH	DH	DA	9/06			


Vaults and Boxes

NOTES:

1. Grounding by customer shall be 2-50' #2 stranded bare copper wires laid in the bottom of the conduit trench in opposite directions with 2-5' tails left in the box.
NOTE: Ground wires shall be installed through a 1" PVC conduit in the structures end walls.
2. For location and clearances to other structures, see RS-5.
3. Retaining wall required when grade from bottom of pad rises or lowers more than 1' in 5' horizontally or when required by developer as perimeter wall.
4. Required easement:



5. If the designer specifies additional conduit openings, the contractor shall core drill the hole as required.
6. The bottom surface of the manhole shall be level.
7. If the ground water level is at least 3' below the bottom of the pull box, the 2" diameter knockout in the sump pump recess shall be removed.
8. If any final grade adjustment "x" is needed, take the following action:
 - A. 0" -6": The top of the pad has to clear the final grade 11" to min. 5".
 - B. 6" -24": The NVE contractor shall order an extension from the original manufacturer.
 - C. Above 24": Any extension exceeding 24" shall be subject to T & D Standards approval.
 - D. If bottom of the manhole pad is located 1" to 24" above a final ground level, the NVE contractor shall make a concrete collar that fills the space under the outside dimensions of the pad.
 - E. If bottom of the manhole pad is located more than 24" above or below ground level, the proposed adjustment shall be subject to T & D Standards approval.
9. This manhole may be installed next to sidewalks, but never under traffic areas.
 For heavy frequency traffic areas, (e.g., streets, roads, etc.) use the RS-94 manhole.

				Electric Service Requirements		RS-98
				12kV Manhole Pad: Adjacent to Public R.O.W.		
Drawn:	Eng:	Appr:	Date:			Revision: 1
DH	DH	DA	9/06			Page 2 of 2