

NV ENERGY APPROVED METERING EQUIPMENT (NORTHERN NEVADA)

UPDATED 7-11-2014

The following equipment has been evaluated and is known to meet NV Energy (Northern Nevada) requirements. Other manufacturers may produce similar equipment that may also meet our requirements provided they conform to EUSERC standards.

Underground Fed Installations 1Ø-3W & 3Ø-4W					
Amperage/Voltage	Component	General Requirements	EUSERC Drawing	Accepted Manufacturers Components	
				Milbank	B-Line/Circle AW
201 - 400A 1Ø-3W					
	Termination Cabinet	10.5"W x 6"D x 22" from bottom of can to lowest termination bolt	343 & 347	PB-014	R9000C
	CT Compartment	20"W x 36"H x 11"D	317	CT203611-HC	203611HRTCT
	CT Mounting Base	Fault rating must match or exceed panel rating	328B	K4793 (10K AIC) or K4797 (50K AIC)	6019A(10K AIC) or 6019HA (50K AIC)
	Meter Socket	12"W x 20"H x 4.5"D	339	UC3436-XL	12146
401 - 800A 1Ø-3W					
	Termination Cabinet	16.5"W x 11"D x 26" from bottom of can to lowest termination bolt	343 & 347	PB-018	R9000E
	CT Compartment	24"W x 48"H x 11"D	317	CT244811-HC	244811HRTCT
	CT Mounting Base	Fault rating must match or exceed panel rating	328B	K4795 (10K AIC) or K4797 (50K AIC)	6019E(10K AIC) or 6019HE (50K AIC)
	Meter Socket	12"W x 20"H x 4.5"D	339	UC3436-XL	12146
201 - 400A 3Ø-4W					
	Termination Cabinet	14"W x 6"D x 22" from bottom of can to lowest termination bolt	343 & 347	PB-034	R9000CC
	CT Compartment	30"W x 36"H x 11"D	318	CT303611-HC	303611HRTCT
	CT Mounting Base	Fault rating must match or exceed panel rating	329B	K4794 (10K AIC) or K4798 (50K AIC)	6067A(10K AIC) or 6067HA (50K AIC)
	Meter Socket	12"W x 20"H x 4.5"D	339	UC3433-XL	121413
401 - 800A 3Ø-4W					
	Termination Cabinet	22"W x 11"D x 26" from bottom of can to lowest termination bolt	343 & 347	PB-038	R9000EE
	CT Compartment	36"W x 48"H x 11"D	318	CT364811-HC	364811HRTCT
	CT Mounting Base	Fault rating must match or exceed panel rating	329B	K4796 (10K AIC) or K4798 (50K AIC)	6067EE(10K AIC) or 6067HEE (50K AIC)
	Meter Socket	12"W x 20"H x 4.5"D	339	UC3433-XL	121413
Overhead Fed Installations 1Ø-3W					
Amperage/Voltage	Component	General Requirements	EUSERC Drawing	Accepted Manufacturers Components	
				Milbank	B-Line/Circle AW
201 - 400A 1Ø-3W					
	CT Compartment	20"W x 36"H x 11"D	317	CT203611-HC	203611HRTCT
	CT Mounting Base	Fault rating must match or exceed panel rating	328B	K4793 (10K AIC) or K4797 (50K AIC)	6019A(10K AIC) or 6019HA (50K AIC)
	Meter Socket	12"W x 20"H x 4.5"D	339	UC3436-XL	12146
401 - 600A 1Ø-3W					
	CT Compartment	24"W x 48"H x 11"D	317	CT244811-HC	244811HRTCT
	CT Mounting Base	Fault rating must match or exceed panel rating	328B	K4795 (10K AIC) or K4797 (50K AIC)	6019E(10K AIC) or 6019HE (50K AIC)
	Meter Socket	12"W x 20"H x 4.5"D	339	UC3436-XL	12146

NV ENERGY APPROVED METERING EQUIPMENT (NORTHERN NEVADA)

UPDATED 7-11-2014

Overhead Fed Installations 3Ø-4W					
Amperage/Voltage	Component	General Requirements	EUSERC Drawing	Accepted Manufacturers Components	
				Milbank	B-Line/Circle AW
0 - 400A 3Ø-4W					
	CT Compartment	30"W x 36"H x 11"D	318	CT303611-HC	303611HRTCT
	CT Mounting Base	Fault rating must match or exceed panel rating	329B	K4794 (10K AIC) or K4798 (50K AIC)	6067A(10K AIC) or 6067HA (50K AIC)
	Meter Socket	12"W x 20"H x 4.5"D	339	UC3433-XL	121413
401 - 600A 3Ø-4W					
	CT Compartment	36"W x 48"H x 11"D	318	CT364811-HC	364811HRTCT
	CT Mounting Base	Fault rating must match or exceed panel rating	329B	K4796 (10K AIC) or K4798 (50K AIC)	6067EE(10K AIC) or 6067HEE (50K AIC)
	Meter Socket	12"W x 20"H x 4.5"D	339	UC3433-XL	121413