

## All Dimensions are in Inches


## NOTES:

- 1. Consult NVE for use of bus bars larger than 5 inches.
- 2. Manufacturer shall secure the removable bus link to the upper and lower current transformer bus units using ½" (grade 5) hex-head steel bolts. Each bolt shall be provided with two Belleville washers installed on opposite sides of the bus units and a nut. Use of Belleville washers requires a label on each phase of the bus link assembly indicating proper torque setting.
- 3. Drill and tap two holes as shown on the outer bus units for ¼" x 20 capscrews.

<b>NV</b> Energy				Electric Service Requirements	RPM-31
				Removable Link & CT Support for	
Drawn:	Eng:	Appr:	Date:	Instrument Transformer with 5" Bus	Revision: 1
DH	DH	DA	1106		Page 1 of 2

**Metering Equipment: Material Requirements** 

THIS PAGE INTENTIONALLY LEFT BLANK



**Electric Service Requirements** 

Removable Link & CT Support for Instrument Transformer with 5" Bus

**RPM-31** 

Revision: 1 Page 2 of 2