



COMMERCIAL ENERGY SERVICES

2017 NEW CONSTRUCTION SPECIFICATION SHEETS

2012 IECC



Table of Contents

1.	Lighting Specifications-5% Better Than IECC 2012	3
1.1.	Lighting Performance-Based Approach	3
1.2.	2012 IECC Building Area Type-Table.....	4
1.3.	2012 IECC Space by Space Area-Table	5
1.4.	2012 IECC Building Area Type, Section C406 Requirements-Table	7
2.	Performance-Based Lighting Specifications- 20% Better Than IECC 2012.....	9
2.1.	Lighting Performance-Based Approach	9
2.2.	2012 IECC Building Area Type-Table.....	10
2.3.	2012 IECC Space by Space Area Type-Table	11
2.4.	2012 IECC Building Area Type Table-Section C406 Requirements	13
3.	Cooling and Miscellaneous Specifications	14
3.1.	Air- and Water-Cooled Units	14
3.2.	Packaged Terminal Units (PTAC/PTHP)	14
3.3.	Variable Speed Drives.....	15
4.	Commercial Kitchens/Refrigeration Specifications	16
4.1.	Fryers	16
4.2.	Large Vat Fryers	16
4.3.	Griddles	16
4.4.	Convection Ovens.....	16
4.5.	Combination Ovens	16
4.6.	Steam Cookers.....	16
4.7.	Holding Cabinets.....	17
4.8.	Ventilation Control-New Hood	17
4.9.	Evaporator Fan	17
4.10.	Ice Machines.....	17
4.11.	Refrigerators/Freezers.....	18
5.	Performance and Whole Building-Based Specifications	19
5.1.	Performance-Based Approach- 5% Better Than IECC 2012.....	19
5.2.	Performance-Based Approach- 20% Better Than IECC 2012.....	19
5.3.	Whole Building Based Approach- 5% Better Than IECC 2012 or ASHRAE 90.1-2010	20
5.4.	Whole Building Based Approach- 5% or 20% Better Than IECC 2012 Or ASHRAE 90.1-2010	21
6.	Time of Use Periods	22
6.1.	Northern NV Energy Time of Use Periods	22
6.2.	Southern NV Energy Time of Use Periods	22

1. Lighting Specifications-5% Better Than IECC 2012

1.1. Lighting Performance-Based Approach

For performance-based lighting, the energy savings will be based on the calculated lighting power density (LPD) on watts per square foot basis using either the Building Area Type method or the Space by Space method. Incentives will be paid only on the square footage of the building where the lighting installation is completed and is ready for occupancy. If a portion of a building is not completed such that final lighting installation is not complete and the space ready for occupancy, then that portion is not eligible for an incentive. IECC 2012 Lighting Standard specifies the allowable light density for each major building area or space type. Please see the Commercial Energy Services Policies and Procedures Manual for more detailed information and example qualification calculation.

The incentive for the lighting performance-based approach is \$450 per kW reduction in connected lighting load below the IECC 2012 standard. The total lighting wattage density must be 5% lower than the IECC 2012 standard to qualify for an incentive. The minimum allowed lighting density used to calculate the incentive shall be at 50% of the IECC required value. Where an applicant has installed a lighting density less than 50% of the IECC standard value, projects will be evaluated on a case by case basis to determine the incentive and whichever approach is used it, will be for the entire incentive related to installed fixtures.

The following documentation is required to support the application:

- Supporting calculations demonstrating building/space area and installed lighting wattage such as COMCheck report or engineering calculations
- Lighting layout plans
- Lighting fixtures schedule including fixture counts and manufacturers specification sheet including model number and rated wattage

Please review the Commercial Energy Services Policies & Procedures for any additional information.

Section C406 - Section C406 of IECC 2012 requires that buildings comply with additional efficiency package options. Efficient Lighting System in accordance with C406.3 and the associated reduced interior lighting power by building area type, shown below, is one method of compliance. If this method is used, the lighting power density for compliance must be used for all lighting areas within the building. Please see IECC 2012 code manual for additional information. Note: If this method is chosen for compliance, exterior lighting qualifications will also apply.

Quick Facts:

- Energy savings is based on the calculated Lighting Power Density (LPD) on a watt per square foot basis using either the Building Area Type method or the Space by Space method.
- The total lighting wattage density must be 5% lower than the IECC 2012 standard to qualify for an incentive.

1.2. 2012 IECC Building Area Type-Table

2012 IECC Building Area Type	IECC Standard Watts/Sq. Ft	CES Design Max Watts/Sq. Ft
Automotive Facility	0.9	0.86
Convention Center	1.2	1.14
Courthouse	1.2	1.14
Dining: Bar Lounge/Leisure	1.3	1.24
Dining: Cafeteria/Fast Food	1.4	1.33
Dining: Family	1.6	1.52
Dormitory	1	0.95
Exercise Center	1	0.95
Fire Station	0.8	0.76
Gymnasium	1.1	1.05
Healthcare-Clinic	1	0.95
Hospital	1.2	1.14
Hotel	1	0.95
Library	1.3	1.24
Manufacturing Facility	1.3	1.24
Motel	1	0.95
Motion Picture Theater	1.2	1.14
Multi-family	0.7	0.67
Museum	1.1	1.05
Office	0.9	0.86
Parking Garage	0.3	0.29
Penitentiary	1	0.95
Performing Arts Theaters	1.6	1.52
Police Station	1	0.95
Post Office	1.1	1.05
Religious Building	1.3	1.24
Retail	1.4	1.33
School/University	1.2	1.14
Sports Arena	1.1	1.05
Town Hall	1.1	1.05
Transportation	1	0.95
Warehouse	0.6	0.57
Workshop	1.4	1.33

1.3. 2012 IECC Space by Space Area-Table

2012 IECC Space by Space Area Type	IECC Standard Watts/Sq. Ft	CES Design Max Watts/Sq. Ft
Atrium - First 40 ft. in height (per ft. ht.)	0.03	0.03
Atrium - Above 40 ft. in height (per ft. ht.)	0.02	0.02
Audience Seating - Auditorium	0.9	0.86
Audience Seating - Performing arts theater	2.6	2.47
Audience Seating - Motion picture theater	1.2	1.14
Audience Seating - Classroom/lecture/training	1.3	1.24
Audience Seating – Conf./meeting/multipurpose	1.2	1.14
Audience Seating - Corridor/transition	0.7	0.67
Dining Area - Bar/lounge/leisure dining	1.4	1.33
Dining Area - Family dining	1.4	1.33
Dressing/fitting room performing arts theater	1.1	1.05
Electrical/mechanical	1.1	1.05
Food Preparation	1.2	1.14
Laboratory for classrooms	1.3	1.24
Laboratory for medical/industrial/research	1.8	1.71
Lobby	1.1	1.05
Lobby for performing arts theater	3.3	3.14
Lobby for motion picture theater	1	0.95
Locker Room	0.8	0.76
Lounge Recreation	0.8	0.76
Office - Enclosed	1.1	1.05
Office - Open plan	1	0.95
Restroom	1	0.95
Sales Area	1.6	1.52
Stairway	0.7	0.67
Storage	0.8	0.76
Workshop	1.6	1.52
Courthouse/police/prison - Courtroom	1.9	1.81
Courthouse/police/prison - Confinement cells	1.1	1.05
Courthouse/police/prison - Judge chambers	1.3	1.24
Courthouse/police/prison - Prison audience seating	0.5	0.48
Courthouse/police/prison - Prison classroom	1.3	1.24
Courthouse/police/prison - Prison dining	1.1	1.05
Automotive - Service/repair	0.7	0.67
Healthcare Clinic/Hosp. - Emergency	2.7	2.57
Healthcare Clinic/Hosp. - Public/staff lounge	0.8	0.76
Healthcare Clinic/Hosp. - Medical supplies	1.4	1.33
Healthcare Clinic/Hosp. - Nursery	0.9	0.86
Healthcare Clinic/Hosp. - Nurse station	1	0.95
Healthcare Clinic/Hosp. - Physical therapy	0.9	0.86
Healthcare Clinic/Hosp. - Patient room	0.7	0.67

2012 IECC Space by Space Area Type	IECC Standard Watts/Sq. Ft	CES Design Max Watts/Sq. Ft
Healthcare Clinic/Hosp. - Pharmacy	1.2	1.14
Healthcare Clinic/Hosp. - Radiology/imaging	1.3	1.24
Healthcare Clinic/Hosp. - Operating room	2.2	2.09
Healthcare Clinic/Hosp. - Recovery	1.2	1.14
Healthcare Clinic/Hosp. - Lounge/recreation	0.8	0.76
Healthcare Clinic/Hosp. - Laundry/washing	0.6	0.57
Hotel - Dining area	1.3	1.24
Hotel - Guest rooms	1.1	1.05
Hotel - Hotel lobby	2.1	2.00
Hotel - Highway lodging dining	1.2	1.14
Hotel - Highway lodging guest room	1.1	1.05
Library - Stacks	1.7	1.62
Library - Card file & cataloguing	1.1	1.05
Library - Reading area	1.2	1.14
Manufacturing - Corridors/transition	0.4	0.38
Manufacturing - Detailed manufacturing	1.3	1.24
Manufacturing - Equipment room	1	0.95
Manufacturing - Extra high bay >50ft	1.1	1.05
Manufacturing - High bay 25-50ft	1.2	1.14
Manufacturing - Low bay <25ft	1.2	1.14
Museum - General exhibition	1	0.95
Museum - Restoration	1.7	1.62
Parking Garage	0.2	0.19
Convention Center - Exhibit space	1.5	1.43
Convention Center - Audience/seating space	0.9	0.86
Fire Station - Engine room	0.8	0.76
Fire Station - Sleeping quarters	0.3	0.29
Post Office - sorting area	0.9	0.86
Religious Bldg. - Fellowship hall	0.6	0.57
Religious Bldg. - Audience seating	2.4	2.28
Religious Bldg. - Worship pulpit/choir	2.4	2.28
Retail - Dressing/fitting area	0.9	0.86
Retail - Mall concourse	1.6	1.52
Retail - Sales area	1.6	1.52
Sports Arena - Audience seating	0.4	0.38
Sports Arena - Court sports-class 4	0.7	0.67
Sports Arena - Court sports-class 3	1.2	1.14
Sports Arena - Court sports-class 2	1.9	1.81
Sports Arena - Court sports-class 1	3	2.85
Sports Arena - Ring sports area	2.7	2.57
Transportation - Air/train/bus baggage area	1	0.95
Transportation - Airport concourse	0.6	0.57
Transportation - Terminal-ticket counter	1.5	1.43
Warehouse - Fine material storage	1.4	1.33
Warehouse - Medium/bulky material	0.6	0.57

2012 IECC Space by Space Area Type	IECC Standard Watts/Sq. Ft	CES Design Max Watts/Sq. Ft
Retail - Mall concourse	1.6	1.52
Retail - Sales area	1.6	1.52
Sports Arena - Audience seating	0.4	0.38
Sports Arena - Court sports-class 4	0.7	0.67
Sports Arena - Court sports-class 3	1.2	1.14
Sports Arena - Court sports-class 2	1.9	1.81
Sports Arena - Court sports-class 1	3	2.85
Sports Arena - Ring sports area	2.7	2.57
Transportation - Air/train/bus baggage area	1	0.95
Transportation - Airport concourse	0.6	0.57
Transportation - Terminal-ticket counter	1.5	1.43
Warehouse - Fine material storage	1.4	1.33
Warehouse - Medium/bulky material	0.6	0.57

1.4. 2012 IECC Building Area Type, Section C406 Requirements-Table

Section C406 Requirements 2012 IECC Building Area Type	IECC Standard Watts/Sq. Ft	CES Design Max Watts/Sq. Ft
Automotive Facility	0.82	0.78
Convention Center	1.08	1.03
Courthouse	1.05	1.00
Dining: Bar Lounge/Leisure	0.99	0.94
Dining: Cafeteria/Fast Food	0.9	0.86
Dining: Family	0.89	0.85
Dormitory	0.61	0.58
Exercise Center	0.88	0.84
Fire Station	0.71	0.67
Gymnasium	1	0.95
Healthcare-Clinic	0.87	0.83
Hospital	1.1	1.05
Hotel/Motel	0.88	0.84
Library	1.18	1.12
Manufacturing Facility	1.11	1.05
Motion Picture Theater	0.83	0.79
Multi-family	0.6	0.57
Museum	1.06	1.01
Office - > 30% daylight area	0.9	0.86
Office - < 30% daylight area	0.85	0.81
Performing Arts Theaters	1.39	1.32
Police Station	0.96	0.91
Post Office	0.87	0.83
Religious Building	1.05	1.00
Retail - > 30% daylight area	1.4	1.33
Retail - < 30% daylight area	1.3	1.24
School/University	0.99	0.94

Section C406 Requirements 2012 IECC Building Area Type	IECC Standard Watts/Sq. Ft	CES Design Max Watts/Sq. Ft
Sports Arena	0.78	0.74
Town Hall	0.92	0.87
Transportation	0.77	0.73
Warehouse	0.6	0.57
Workshop	1.2	1.14

2. Performance-Based Lighting Specifications- 20% Better Than IECC 2012

2.1. Lighting Performance-Based Approach

For Performance-Based Lighting, the energy savings will be based on the calculated lighting power density (LPD) on watts per square foot basis using either the Building Area Type method or the Space by Space method. Incentives will be paid only on the square footage of the building where the lighting installation is completed and is ready for occupancy. If a portion of a building is not completed such that final lighting installation is not complete and the space ready for occupancy, then that portion is not eligible for an incentive. IECC 2012 Lighting Standard specifies the allowable light density for each major building area or space type. Please see the Commercial Energy Services Policies and Procedures Manual for more detailed information and example qualification calculation.

The incentive for the lighting performance-based approach is \$550 per kW reduction in connected lighting load below the IECC 2012 standard. The total lighting wattage density must be 20% lower than the IECC 2012 standard to qualify for an incentive. The minimum allowed lighting density used to calculate the incentive shall be at 50% of the IECC required value. Where an applicant has installed a lighting density less than 50% of the IECC standard value, projects will be evaluated on a case by case basis to determine the incentive and whichever approach is used it, will be for the entire incentive related to installed fixtures.

The following documentation is required to support the application:

- Supporting calculations demonstrating building/space area and installed lighting wattage such as COMcheck report or engineering calculations
- Lighting layout plans
- Lighting fixtures schedule including fixture counts and manufacturers specification sheet including model number and rated wattage
- Please review the Commercial Energy Services Policies & Procedures for additional information.

Section C406 - Section C406 of IECC 2012 requires that buildings comply with an additional efficiency package option. Efficient Lighting System in accordance with C406.3 and the associated reduced interior lighting power by building area type, shown below, is one method of compliance. If this method is used, the lighting power density for compliance must be used for all lighting areas within the building. Please see IECC 2012 code manual for additional information. **Note:** If this method is chosen for compliance, exterior lighting qualifications will also apply.

Quick Facts:

- Energy savings will be based on the calculated LPD on a watt per square foot basis.
- The total lighting wattage density must be 20% lower than the IECC 2012 standard to qualify for an incentive.
- The minimum allowed lighting density used to calculate the incentive shall be at 50% of the IECC required value.

2.2. 2012 IECC Building Area Type-Table

2012 IECC Building Area Type	IECC Standard Watts/Sq. Ft	CES Design Max Watts/Sq. Ft
Automotive Facility	0.9	0.72
Convention Center	1.2	0.96
Courthouse	1.2	0.96
Dining: Bar Lounge/Leisure	1.3	1.04
Dining: Cafeteria/Fast Food	1.4	1.12
Dining: Family	1.6	1.28
Dormitory	1	0.80
Exercise Center	1	0.80
Fire Station	0.8	0.64
Gymnasium	1.1	0.88
Healthcare-Clinic	1	0.80
Hospital	1.2	0.96
Hotel	1	0.80
Library	1.3	1.04
Manufacturing Facility	1.3	1.04
Motel	1	0.80
Motion Picture Theater	1.2	0.96
Multi-family	0.7	0.56
Museum	1.1	0.88
Office	0.9	0.72
Parking Garage	0.3	0.24
Penitentiary	1	0.80
Performing Arts Theaters	1.6	1.28
Police Station	1	0.80
Post Office	1.1	0.88
Religious Building	1.3	1.04
Retail	1.4	1.12
School/University	1.2	0.96
Sports Arena	1.1	0.88
Town Hall	1.1	0.88
Transportation	1	0.80
Warehouse	0.6	0.48
Workshop	1.4	1.12

2.3. 2012 IECC Space by Space Area Type-Table

2012 IECC Space by Space Area Type	IECC Standard Watts/Sq. Ft	CES Design Max Watts/Sq. Ft
Atrium - First 40 ft. in height (per ft. ht.)	0.03	0.02
Atrium - Above 40 ft. in height (per ft. ht.)	0.02	0.02
Audience Seating - Auditorium	0.9	0.72
Audience Seating - Performing arts theater	2.6	2.08
Audience Seating - Motion picture theater	1.2	0.96
Audience Seating - Classroom/lecture/training	1.3	1.04
Audience Seating - Conf/meeting/multipurpose	1.2	0.96
Audience Seating - Corridor/transition	0.7	0.56
Dining Area - Bar/lounge/leisure dining	1.4	1.12
Dining Area - Family dining	1.4	1.12
Dressing/fitting room performing arts theater	1.1	0.88
Electrical/mechanical	1.1	0.88
Food Preparation	1.2	0.96
Laboratory for classrooms	1.3	1.04
Laboratory for medical/industrial/research	1.8	1.44
Lobby	1.1	0.88
Lobby for performing arts theater	3.3	2.64
Lobby for motion picture theater	1	0.80
Locker Room	0.8	0.64
Lounge Recreation	0.8	0.64
Office - Enclosed	1.1	0.88
Office - Open plan	1	0.80
Restroom	1	0.80
Sales Area	1.6	1.28
Stairway	0.7	0.56
Storage	0.8	0.64
Workshop	1.6	1.28
Bank/Office - Banking activity area	1.5	1.20
Dormitory Living Quarters	1.1	0.88
Gymnasium/Fitness - Fitness area	0.9	0.72
Gymnasium/Fitness - Gym audience seating	0.4	0.32
Gymnasium/Fitness - Playing area	1.4	1.12
Healthcare Clinic/Hosp. - Corridors/transition	1	0.80
Healthcare Clinic/Hosp. - Exam/treatment	1.7	1.36
Healthcare Clinic/Hosp. - Emergency	2.7	2.16
Healthcare Clinic/Hosp. - Public/staff lounge	0.8	0.64
Healthcare Clinic/Hosp. - Medical supplies	1.4	1.12
Healthcare Clinic/Hosp. - Nursery	0.9	0.72
Healthcare Clinic/Hosp. - Patient room	0.7	0.56
Healthcare Clinic/Hosp. - Pharmacy	1.2	0.96
Healthcare Clinic/Hosp. - Radiology/imaging	1.3	1.04
Healthcare Clinic/Hosp. - Operating room	2.2	1.76
Healthcare Clinic/Hosp. - Recovery	1.2	0.96

Healthcare Clinic/Hosp. - Lounge/recreation	0.8	0.64
Healthcare Clinic/Hosp. - Laundry/washing	0.6	0.48
Hotel - Dining area	1.3	1.04
Hotel - Guest rooms	1.1	0.88
Hotel - Hotel lobby	2.1	1.68
Hotel - Highway lodging dining	1.2	0.96
Hotel - Highway lodging guest room	1.1	0.88
Library - Stacks	1.7	1.36
Library - Card file & cataloguing	1.1	0.88
Library - Reading area	1.2	0.96
Manufacturing - Corridors/transition	0.4	0.32
Manufacturing - Detailed manufacturing	1.3	1.04
Manufacturing - Equipment room	1	0.80
Manufacturing - Extra high bay >50ft	1.1	0.88
Manufacturing - High bay 25-50ft	1.2	0.96
Manufacturing - Low bay <25ft	1.2	0.96
Museum - General exhibition	1	0.80
Museum - Restoration	1.7	1.36
Parking Garage	0.2	0.16
Convention Center - Exhibit space	1.5	1.20
Convention Center - Audience/seating space	0.9	0.72
Fire Station - Engine room	0.8	0.64
Fire Station - Sleeping quarters	0.3	0.24
Post Office - sorting area	0.9	0.72
Religious Bldg. - Fellowship hall	0.6	0.48
Religious Bldg. - Audience seating	2.4	1.92
Religious Bldg. - Worship pulpit/choir	2.4	1.92
Retail - Dressing/fitting area	0.9	0.72
Retail - Mall concourse	1.6	1.28
Retail - Sales area	1.6	1.28
Sports Arena - Audience seating	0.4	0.32
Sports Arena - Court sports-class 4	0.7	0.56
Sports Arena - Court sports-class 3	1.2	0.96
Sports Arena - Court sports-class 2	1.9	1.52
Sports Arena - Court sports-class 1	3	2.40
Sports Arena - Ring sports area	2.7	2.16
Transportation - Air/train/bus baggage area	1	0.80
Transportation - Airport concourse	0.6	0.48
Transportation - Terminal-ticket counter	1.5	1.20
Warehouse - Fine material storage	1.4	1.12
Warehouse - Medium/bulky material	0.6	0.48

2.4. 2012 IECC Building Area Type Table-Section C406 Requirements

Section C406 Requirements 2012 IECC Building Area Type	IECC Standard Watts/Sq. Ft	CES Design Max Watts/Sq. Ft
Automotive Facility	0.82	0.66
Convention Center	1.08	0.86
Courthouse	1.05	0.84
Dining: Bar Lounge/Leisure	0.99	0.79
Dining: Cafeteria/Fast Food	0.9	0.72
Dining: Family	0.89	0.71
Dormitory	0.61	0.49
Exercise Center	0.88	0.70
Fire Station	0.71	0.57
Gymnasium	1	0.80
Healthcare-Clinic	0.87	0.70
Hospital	1.1	0.88
Hotel/Motel	0.88	0.70
Library	1.18	0.94
Manufacturing Facility	1.11	0.89
Motion Picture Theater	0.83	0.66
Religious Building	1.05	0.84
Automotive Facility	0.82	0.66
Convention Center	1.08	0.86
Courthouse	1.05	0.84
Dining: Bar Lounge/Leisure	0.99	0.79
Dining: Cafeteria/Fast Food	0.9	0.72
Dining: Family	0.89	0.71
Dormitory	0.61	0.49
Exercise Center	0.88	0.70
Fire Station	0.71	0.57
Gymnasium	1	0.80
Healthcare-Clinic	0.87	0.70
Hospital	1.1	0.88
Hotel/Motel	0.88	0.70
Library	1.18	0.94
Manufacturing Facility	1.11	0.89
Motion Picture Theater	0.83	0.66
Religious Building	1.05	0.84
Retail - > 30% daylight area	1.4	1.12
Retail - < 30% daylight area	1.3	1.04
School/University	0.99	0.79
Sports Arena	0.78	0.62
Town Hall	0.92	0.74
Transportation	0.77	0.62
Warehouse	0.6	0.48
Workshop	1.2	0.96

3. Cooling and Miscellaneous Specifications

3.1. Air- and Water-Cooled Units

New air- and water-cooled air conditioning units or heat pumps that meet or exceed the qualifying efficiency (EER) shown in the Cooling Incentive Tech Sheet Table are eligible for an incentive. These units can be either split system or single packaged units. Evaporative coolers do not qualify under the New Construction Prescriptive Air Conditioning Incentive, but may qualify under the New Construction Performance-Based Service. All packaged and split system cooling equipment must meet Air-Conditioning, Heating and Refrigeration Institute (AHRI) standards (210/240, 320 or 340/360), be UL listed, and use a minimum ozone-depleting refrigerant (e.g., HCFC or HFC). A manufacturer's specification sheet indicating the system efficiency must accompany the application.

The total incentive is determined by two components – an equipment incentive and an efficiency incentive. Both the equipment and efficiency incentives are applied per ton of cooling installed. The equipment qualifies for an equipment incentive if the qualifying efficiency is met for the equipment size category. In addition, the efficiency incentive is added on a prorated basis if the equipment exceeds the minimum qualifying efficiency for the equipment size category.

The incentive for air conditioners is calculated as follows:

Tons X [Equipment Incentive/ton + Efficiency Incentive/ton X (EER new – EER qualifying)]

For air-cooled units =<65,000 Btuh, the SEER value must be entered for both the Unit Efficiency and the Qualifying Efficiency to calculate the incentive amount. The EER value for air-cooled units =<65,000 Btuh must also be entered under the column heading labeled "EER Value for Units =<65,000 Btuh." For all other sizes of air-cooled units, use the EER values in the Unit Efficiency and Qualifying Efficiency columns; it is not necessary to enter the EER Value under the column heading labeled "EER Value for Units =<65,000 Btuh."

NOTE: When choosing the Efficient HVAC Performance option for Section C406 of IECC 2012, it is required that the increased.

Quick Facts:

- Evaporative coolers do not qualify under the New Construction Prescriptive Air Conditioning Incentive, but may qualify under the New Construction Performance-Based Service.
- All packaged and split system cooling equipment must meet Air-Conditioning, Heating and Refrigeration Institute standards (210/240, 320 or 340/360), be UL listed, and use a minimum ozone-depleting refrigerant (e.g., HCFC or HFC).

3.2. Packaged Terminal Units (PTAC/PTHP)

Package terminal air conditioners and heat pumps are through-the-wall self-contained units that are two tons (24,000 Btuh or less). Such units cool small areas and are commonly used for individual rooms. Only units that have an EER greater than or equal to $[13.08 - (0.2556 \times \text{capacity in Btu/h} / 1000)]$ qualify for an incentive. All EER values shall be rated at 95 °F outdoor dry-bulb temperature. These units have a combination of heating and cooling assemblies intended for mounting through the wall. It includes refrigeration, outdoor louvers, forced ventilation, and may connect to external heating source or have electric resistance heating.

Quick Facts:

- Two tons (24,000 Btuh) or less.
- All EER values shall be rated at 95 °F outdoor dry-bulb temperature.

3.3. Variable Speed Drives

Variable speed drives (VSD) offer a method of significantly reducing the energy consumed by fans, centrifugal pumps, and other motor driven machinery operating under varying loads. VSD must be installed for the primary purpose of reducing energy usage.

Prescriptive incentives are available for applications < 200 HP on qualifying HVAC fans (supply, return, exhaust, make up), single speed cooling tower fans, chilled/condenser water circulation pumps (HVAC), hot water circulation pumps (HVAC), boiler feed water pumps as well as for installations on process related machinery. Equipment must operate a minimum of 1500 hours. Integrated VSD applications on new chillers or package units are not eligible for this incentive.

VSDs on process equipment are not eligible for this measure and must utilize the Performance-Based Technology Form.

For instances where VSDs are installed on redundant/backup systems (such as secondary chilled water pumps), only one unit is eligible for an incentive.

Application Code for eligible VSD applications:

BEF = Building Exhaust Fan

CTF = Cooling Tower Fan

CWP = Chilled/Condenser Water Pump

FWP = Boiler Feed Water Pump

HWP = Hot Water Circulator Pump

MAF = Make-up Air Fan

RFA = Return fan on return air handler

SFA = Supply fan on supply air handler

NOTE: VSD applications required by IECC 2012 are not eligible for incentives. VSDs on all VAV fan installations > 7.5 HP are not eligible as they are required by IECC 2012. Variable speed fans are required by IECC 2012 on cooling tower fans > 7.5 HP and are not eligible for incentives. Hydronic systems greater than or equal to 300,000 btu/h in design output capacity supplying heated or chilled water to comfort conditioning systems must have flow control capabilities (which can be satisfied with a VSD).

Quick Facts:

- Prescriptive incentives are available for applications \leq 200 HP on qualifying HVAC fans, single speed cooling tower fans, chilled/condenser water circulation pumps, hot water circulation pumps, boiler feed water pumps as well as for installations on process related machinery
- VSDs on process equipment are not eligible for this measure and must utilize the Performance-Based Technology Form.

4. Commercial Kitchens/Refrigeration Specifications

Only electric equipment qualifies for incentives. ENERGY STAR® maintains a list of qualifying products and specifications at www.energystar.gov or www.CEE1.org. To determine if non-ENERGY STAR models meet the ASTM standard, contact your manufacturer's representative.

4.1. Fryers

The fryer shall meet or exceed ENERGY STAR specifications which are a heavy load cooking energy efficiency of > 80% utilizing American Society for Testing and Materials (ASTM) Standard F1361 and a normalized idle energy rate ≤ 1,000 watts (based on a 15-inch fryer).

4.2. Large Vat Fryers

The commercial fryer shall have a tested heavy load (French fry for large vats) cooking energy efficiency of > 80% utilizing ASTM Standard F2144 for large vat fryers. Multiple vat configurations are paid per qualifying vat.

4.3. Griddles

The griddle shall meet or exceed ENERGY STAR specifications which are a heavy load cooking energy efficiency of > 70% utilizing ASTM Standard F1275 and a normalized idle energy rate ≤ 320 watts per ft².

4.4. Convection Ovens

The oven shall meet or exceed ENERGY STAR specifications which are a heavy load potato cooking energy efficiency of > 70% utilizing ASTM Standard F1496 and an idle energy rate of ≤ 1.0 kW for half size and ≤ 1.6 kW for full size.

4.5. Combination Ovens

The oven shall meet or exceed heavy load cooking energy efficiency of > 60% utilizing ASTM Standard F1639.

4.6. Steam Cookers

The commercial steam cooker shall meet ENERGY STAR specifications for energy efficiency or shall have a tested heavy load potato cooking energy efficiency of > 50% utilizing ASTM Standard F1484.

Pan Capacity	Idle Rate (watts)
3-pan	400
4-pan	530
5-pan	670
6-pan or larger	800

4.7. Holding Cabinets

This measure does not include cook and hold equipment. All measures shall be electric hot food holding cabinets that are fully insulated and have solid doors in full, three-quarter and half sizes respectively. Qualifying cabinets shall not exceed the maximum idle energy rate of 20 watts per cubic foot in accordance with the ASTM Standard F2140 test method as stated in ENERGY STAR. Cook and hold equipment and units < ½ size may be eligible and should be applied for as a custom incentive.

4.8. Ventilation Control-New Hood

This incentive applies toward the purchase and installation of a new commercial kitchen exhaust hood control system installed in a new dedicated commercial kitchen exhaust hood and make-up air system. The incentive is per exhaust fan hp. The control system must be used in conjunction with variable speed fan motor controls. Only pre-approved control systems will qualify for an incentive. Please see the Commercial Energy Services Service Policies and Procedures for details on approved control systems.

4.9. Evaporator Fan

This measure is for the installation of controls in medium temperature walk-in coolers. The controller reduces airflow of the evaporator fans when there is no refrigerant flow. The measure must control a minimum of 1/20 HP where fans operate continuously at full speed. The measure also must reduce fan motor power by at least 75% during the off cycle. This measure is NOT applicable if any of the following conditions apply:

- 1) The compressor runs all the time with high duty cycle
- 2) The evaporator fan does not run at full speed all the time
- 3) The evaporator fan motor runs on polyphase power
- 4) The evaporator fan motor is not shaded-pole or permanent split capacitor
- 5) Evaporator does not use off-cycle or time-off defrost

4.10. Ice Machines

This specification covers machines generating 60 grams (2 oz.) or lighter ice cubes, as well as flaked, crushed and fragmented ice makers. Performance data is based on Air-Conditioning, Heating and Refrigeration Institute (AHRI) Standard 810. Air-cooled (self-contained, ice making heads, or remote condensing) or Water-cooled machines with an independent and isolated compressor and ice formation feeds on a closed-chilled water loop are eligible. The efficiency specifications for the two qualifying tiers are equivalent to ENERGY STAR/or CEE Tier 2. The entire AHRI tested ice making system must be purchased to qualify. Remote machines shall be purchased with qualifying remote condenser or remote condenser/compressor unit. Visit www.ahrinet.org for product information and testing procedures. Specifications are available at <http://www.energystar.gov> or www.cee1.org. The test method must be in accordance with AHRI Standard 810.

Quick Facts:

- The entire AHRI tested ice making system must be purchased to qualify.
- The efficiency specifications for the two qualifying tiers are equivalent to ENERGY STAR/or CEE Tier 2.

4.11. Refrigerators/Freezers

The refrigeration system shall be a new built-in (packaged) unit. Cases with remote refrigeration systems do not qualify for a prescriptive incentive. Customers shall provide proof that the appliance meets the ENERGY STAR Version 2.0 specifications using ANSI/ASHRAE Standard 72-2005 (38 °F +/- 2 °F for refrigerators and 0 °F +/- 2 °F for freezers). Please see the Commercial Energy Services Policy and Procedures for energy usage specifications.

NOTE: If a refrigeration measure is required by code, it is not eligible for an incentive.

5. Performance and Whole Building-Based Specifications

These specifications refer to the 2012 version of the IECC. The code for the jurisdiction under which a project is permitted will be the applicable code.

5.1. Performance-Based Approach- 5% Better Than IECC 2012

The Performance-Based Approach enables the design team to consider a custom approach for individual items, such as a high efficiency chiller. Documentation of savings in the form of a building performance model or appropriate engineering algorithms must be provided by the applicant and must show that the annual energy consumption is at least 5% better than the IECC 2012 minimum. The incentive rate is based on kWh savings and varies for on-peak and non on-peak periods. (More detailed information is contained in the Commercial Energy Services Policies and Procedures document.)

Please refer to the Commercial Energy Services Policies & Procedures Manual Appendix for guidelines on supporting documentation required for different project types. Note that the information below is required to confirm kWh savings. Examples of documentation to be included with the application are:

- A narrative or list of specific energy efficient features of the building and listing the energy efficient system performance and comparing it to IECC 2012 minimum system performance.
- A description of the building schedule and major operating assumptions.
- The input and output files used for the model annotated to show the base case and where the energy efficient features are included. Industry accepted modeling tools such as eQUEST, DOE-2, Trane Trace, etc. can be used for building simulation purposes.
- A summary worksheet summarizing the results of the modeling and showing annual energy savings and summer peak demand savings between the high-efficiency case and the IECC 2012 minimum.

By providing as much of the information given in the guidelines as possible, the timeframe for project approval will likely be reduced.

Quick Facts:

- The incentive rate is based on kWh savings and varies for on-peak and non on-peak periods.

5.2. Performance-Based Approach- 20% Better Than IECC 2012

Incentives are available for individual projects that operate at a minimum of 20% better than IECC 2012. Documentation of savings in the form of a performance model or appropriate engineering algorithms must be provided by the applicant and must show that the annual energy consumption is at least 20% lower than the IECC 2012 standard. The incentive is based on kWh savings and varies for on-peak and non on-peak periods. No final applications for this measure will be accepted without meeting the above requirements.

Quick Facts:

- **ALL OTHER REQUIREMENTS LISTED ABOVE FOR THE PERFORMANCE-BASED APPROACH - 5% BETTER THAN IECC 2012 MUST ALSO BE MET**
- Customers may not apply for this incentive AND the Performance-Based Approach - 5% better than IECC 2012 as the incentive for this measure includes building to 5% better than IECC 2012.
- A Pre-Notification Application is required no later than the schematic phase of the project.
- The incentive is based on kWh savings and varies for on-peak and non on-peak periods.

5.3. Whole Building Based Approach- 5% Better Than IECC 2012 or ASHRAE 90.1-2010

The Whole Building-Based Approach enables the design team to consider a custom approach for either the building as a whole such as required for LEED qualifications or a combination of measures on a whole building level. Documentation of savings in the form of a building performance model or appropriate engineering algorithms must be provided by the applicant. The standard reference design and proposed design shall be configured and analyzed as specified by either the Section C407 of IECC 2012 or ASHRAE/IESNA Standard 90.1-2010 using the Building Performance Rating Method in Appendix G. Compliance software tools shall generate a report that demonstrates at least 5% percentage improvement in the proposed design compared to the standard reference design. The incentive rate is based on kWh savings and varies for on-peak and non on-peak periods.

Please refer to the Commercial Energy Services Policies & Procedures Manual Appendix for guidelines on supporting documentation required for this approach. Note that this information is required to confirm kWh savings. Examples of documentation to be included with the application are:

- Input and output report(s) from the energy analysis simulation containing the complete input and output files, as applicable.
- An explanation of any error or warning messages appearing in the simulation tool output
- Documentation of the building component characteristic of the standard reference design and proposed design
- A narrative or list of specific energy efficient features of the building listing the energy efficient system performance and comparing it to IECC 2012 minimum system performance.
- A description of the building schedule and major operating assumptions.
- Industry accepted modeling tools such as eQUEST, DOE-2, Trane Trace, etc. can be used for building modeling purposes.
- A summary worksheet summarizing the results of the modeling and showing annual energy savings and summer peak demand savings between the high-efficiency case and the IECC 2012 minimum.

By providing as much of the information given in the guidelines as possible, the timeframe for project approval will likely be reduced.

Quick Facts:

- The incentive rate is based on kWh savings and varies for on-peak and non on-peak periods.

5.4. Whole Building Based Approach- 5% or 20% Better Than IECC 2012 Or ASHRAE 90.1-2010

Incentives are available for projects that apply for the Whole Building-Based approach. Customers that apply for this incentive must be building to at least 5% better than IECC 2009 or ASHRAE 90.1 - 2010 for the energy use of the whole building. Additional incentives are available for building to at least 20% better than IECC 2012 or ASHRAE 90.1 - 2010 for the energy use of the whole building.

There are two methods that can be used to apply for this incentive. Customers may agree to have a Commercial Energy Services team member participate in the design process OR project owners agree to have a Commercial Energy Services Member perform the incremental performance modeling of measures being considered based on modeling that will be done to meet IECC 2012 or ASHRAE 90.1 - 2010 requirements as applicable. The model used, with inputs needed to meet code, must be provided to the Commercial Energy Services team to perform the incremental modeling of measures.

Customers may not apply for this incentive AND the Whole Building Approach - 5% better than IECC 2012 or ASHRAE 90.1 - 2010 as the incentive for this measure includes building to 5% better than IECC 2012 or ASHREAE 90.1 - 2010.

Quick Facts:

- Customers may agree to have a Commercial Energy Services team member participate in the design process OR project owners agree to have a Commercial Energy Services Member perform the incremental performance modeling of measures being considered based on modeling that will be done to meet IECC 2009 requirements as applicable.

6. Time of Use Periods

NOTE: Please contact the Commercial Energy Services team for worksheets that may assist with the division of kWh into on-peak and non-on peak time periods.

6.1. Northern NV Energy Time of Use Periods

Summer On-peak Period:

1 p.m. to 6 p.m. (July 1 through Sept. 30); Monday through Friday only

Winter On-peak Period:

5 p.m. to 9 p.m. (Oct. 1 through June 30); 7 days/week

6.2. Southern NV Energy Time of Use Periods

Summer On-peak Period:

1 p.m. to 7 p.m. (June 1 through Sept. 30); 7 days/week

All other hours are in the Non On-Peak period

Please refer to the Commercial Energy Services Policy and Procedures definitions page for a description of the Northern and Southern Service Territories.