

RULE NO. 2

DESCRIPTION OF SERVICE

A. Delivery Pressures

1. Standard Delivery Pressures

The Standard Delivery Pressure shall be the pressure maintained at the outlet of Customers' meters and shall be approximately eleven (11) inches of water column for LP gas and six (6) inches of water column for natural gas, both above atmospheric pressure and subject to variations due to load conditions.

2. Other Pressures

Upon request, Utility, at its option, may supply pressures in excess of the Standard Delivery Pressure.

B. Heating Value

The heating value of gas supplied herein shall be approximately 2,520 BTU per cubic foot for LP gas and 1,060 BTU per cubic foot for natural gas, both measured on a dry basis at a temperature of 60° F. and a pressure of 14.73 psia.

C. Specific Gravity

The specific gravity of gas supplied herein shall be approximately 1.52 for LP gas and 0.65 for natural gas, both measured at a temperature of 60° F. and a pressure of 14.73 psia.

ISSUED: June 6, 1966

EFFECTIVE: June 27, 1966

Issued By:
Neil W. Plath
President