
**CONSTRUCTION NOTES**

1. Installation: Box to be placed on 6" of 3/4" clean drain rock.
2. Lid to be marked "NVE ELECTRIC" and secured with penta head bolts.
3. to be used on non-Deliberate traffic areas only.
4. Box, extension, and lid shall meet the loading of ANSI/SCTE 77 Tier 22. Box shall be manufactured of concrete with a UV resistant polypropylene cap.

				Volume 17: Electric Service Requirements		VB0052U
				17" X 30" Box		
Drawn:	Eng:	Appr:	Date:			Revision: 9
PR	NP	HW	12/24			Page 1 of 1