



CONSTRUCTION NOTES

- 1. Installation: Box to be placed on 6" of 3/4" clean drain rock that extends 6" minimum past the outside of the box and compacted to 95% maximum density. Concrete Footing around and under shall be installed per detail above.
- 2. Box requires 2 extensions.
- 3. Lid to be marked "NVE ELECTRIC" and secured with penta head bolts.
- 4. Lid shall have pick guards for each pick point.
- 5. Designers: Maximum conductor information is given in CAB09U, Volume 5.

NV Energy.				Volume 17: Engineering & Construction Standard	VB0057M
				17" X 30" Box H-20 Traffic Concrete	
Drawn:	Eng:	Appr:	Date:	(Special Use Only)	Revision: 07
PR	MB	HW	02/25		Page 1 of 1