

CONSTRUCTION NOTES

- 1. Installation: Box to be placed on 6" of 3/4" clean drain rock.
- 2. Lid to be marked "NVE ELECTRIC" and secured with penta head bolts.
- 3. To be used in non-deliberate traffic areas only.
- 4. Box, extension, and lid shall meet the loading of ANSI/SCTE 77 Tier 22.
- 5. Designers: Maximum conductor information is given in CAB09U, Volume 5.

| NVE | DESCRIPTION | APPROVED MANUFACTURERS | | |
|---------|----------------------------------|------------------------|-----------------|----------------------|
| STOCK# | DESCRIPTION | JENSEN | NEWBASIS | ARMORCAST |
| 24-0460 | TIER 22 BOX AND LID | 200070490 | PCA304836-20039 | A6001430HDAPCX36-NVE |
| 24-1190 | REPLACEMENT TIER 22 LID 2 PIECES | 200056813 | PCC3048P2-00086 | A6001470HDA |

| NV Energy _® | | | rav | Volume 17: Electrical Service Requirements | VB0060U |
|-------------------------------|------|-------|-------------------|--|-------------|
| | | | ı gy _® | 30"X 48" Box Polymer | |
| Drawn: | Eng: | Appr: | Date: | OU X 40 BOX 1 Olymor | Revision: 4 |
| PR | NP | HW | 3/25 | | Page 1 of 1 |