



MATERIAL LIST

| STOCK # | QTY. | DESCRIPTION                                         |
|---------|------|-----------------------------------------------------|
| 45-1210 | 1.0  | NIPPLE PIPE 1" X 1 1/2" BLACK                       |
| 45-1310 | 1.0  | NIPPLE PIPE 1 1/4" X 1 1/2" BLACK                   |
| 45-1830 | 1.0  | REDUCER 2" X 1 1/4" BLACK                           |
| 45-1530 | 1.0  | NIPPLE PIPE 2" X 3" BLACK                           |
| 45-0760 | 1.0  | ELBOW BLACK 90 DEGREE 2"                            |
| 45-1103 | 1.0  | MANIFOLD 3-METER 2" SCH 40 PIPE W/3" X 3/4" OUTLETS |
| 43-0040 | 3.0  | COCK GAS METER 3/4"                                 |
| 45-0720 | 3.0  | ELBOW BLACK 90 DEGREE 3/4"                          |
| 45-1110 | 3.0  | NIPPLE PIPE 3/4" X 1 1/2" BLACK                     |
| 45-1206 | 3.0  | NIPPLE PIPE 3/4" X 12" BLACK                        |
| 45-2100 | 3.0  | TEE PIPE 3/4" BLACK                                 |
| 45-1710 | 3.0  | PLUG PIPE 3/4" BLACK                                |

NOTES:

- A) THIS COMPATIBLE UNIT REQUIRES A 1" RISER.
- B) DASHED LINE REPRESENTS MINIMUM SPACE REQUIREMENTS FOR THIS METER SET.
- C) REGULATOR AND ORIFICE TO BE SIZED AND DISTRIBUTED BY THE GAS METER SHOP.
- D) HOUSE LINES MUST HAVE METAL TAG STAMPED WITH ADDRESS.
- E) CUSTOMER SHALL STUB OUT HOUSE LINES 4" FROM FINISH FACE OF BUILDING AND INSTALL 3/4" 90 DEGREE ELBOWS HAND TIGHT.
- F) DIMENSIONS ABOVE ARE MINIMUM REQUIREMENTS FOR METER ACCESSIBILITY. ADDITIONAL GAS METER LOCATION REQUIREMENTS IN SECTION 6 OF THIS VOLUME MUST ALSO BE ADHERED TO.



ENGINEERING & CONSTRUCTION STANDARD

SECTION 5 GAS CONSTRUCTION DRAWINGS  
 GAS METER INSTALLATIONS  
 250 CFH  
 3 METERS

SHEET 5 OF 55

DRAWING NUMBER

**GMI03G**

| DRAWN | DESIGN | SUPR | DATE | REV  |
|-------|--------|------|------|------|
| GD    | KS     | DS   | 5/98 | 7/06 |