



- NOTES: A) THIS COMPATIBLE UNIT REQUIRES A 1" RISER.
 B) DASHED LINE REPRESENTS SPACE REQUIREMENTS FOR THIS METER SET.
 C) REGULATOR AND ORIFICE TO BE SIZED AND DISTRIBUTED BY THE GAS METER SHOP.
 D) ROOTS ROTARY METERS & PHILPOTT FILTERS ARE ITEMS WHICH MUST BE SPECIAL ORDERED THROUGH THE GAS METER SHOP.
 E) CUSTOMER SHALL STUB OUT 4" FROM FINISH FACE OF BUILDING WITH 1 1/2" STEEL PIPE AND INSTALL AN 1 1/2" 90 DEGREE ELBOW HAND TIGHT.
 F) DIMENSIONS ABOVE ARE MINIMUM REQUIREMENTS FOR METER ACCESSIBILITY. ADDITIONAL GAS METER LOCATION REQUIREMENTS IN SECTION 6 OF THIS VOLUME MUST ALSO BE ADHERED TO.

MATERIAL LIST

STOCK #	QTY.	DESCRIPTION
45-1220	2.0	NIPPLE PIPE 1" X 2" BLACK
45-1320	1.0	NIPPLE PIPE 1-1/4" X 2" BLACK
45-0815	1.0	ELBOW REDUCING BLACK 1-1/2" X 1-1/4"
45-1460	1.0	NIPPLE PIPE 1-1/2" X 4" BLACK
45-4015	2.0	UNION INSULATED BLACK 1-1/2"
45-1505	1.0	NIPPLE PIPE 1-1/2" X 8" BLACK
45-0750	2.0	ELBOW BLACK 90 DEGREE 1-1/2"
45-1420	2.0	NIPPLE PIPE 1-1/2" X 2" BLACK
43-0070	1.0	COCK GAS METER 1-1/2"
45-2185	1.0	TEE REDUCING 1-1/2" X 1-1/2" X 3/4" BLACK
45-1140	1.0	NIPPLE PIPE 3/4" X 3" BLACK
43-0040	1.0	COCK GAS METER 3/4"
45-1710	1.0	PLUG PIPE 3/4" BLACK
45-1410	1.0	NIPPLE PIPE 1-1/2" X CLOSE BLACK



ENGINEERING & CONSTRUCTION STANDARD

SECTION 5 GAS CONSTRUCTION DRAWINGS
 GAS METER INSTALLATIONS

METER SET

8 C

SHEET 28 OF 55

DRAWING NUMBER

GMI21G

DRAWN	DESIGN	SUPR	DATE	REV
GD	KS	DS	5/98	7/06